

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
2319 DORRIS PLACE
LOS ANGELES, CA 90031

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

Steve Molinari
Jensen Instruments Co.
643 South Duggan Avenue
Azusa, CA 91702-5185

Telephone: 626-969-7991

Models:

JIC-RS100

File Number: M-070154

Effective Date: 12/01/2009

Expiration Date: 12/01/2010

Manufacturer: SAME

Item: RAIN WATER DIVERSION VALVE &
RAINSWITCH

RECEIVED JAN 28 2009
RECEIVED JAN 28 2009

PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.


This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.


CONDITIONS OF APPROVAL:

1. This valve may be installed in a storm water system, where accessible for inspection and maintenance, outside of a commercial or residential building structure.
2. Storm water drainage piping plans shall be submitted to Mechanical Plan check and permit shall be obtained prior to installation of this valve, in compliance with Los Angeles Plumbing Code, 2008 Edition.
3. A permit from Watershed Protection Division (Phone: 213-482-7066), Department of Public Works shall be required for each installation.

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.


Mark K Wang
Mechanical Testing Laboratory, Test Engineer


Mechanical Testing Laboratory